RESOLUTION NO. 132-2023 APPROVING PROPOSAL FROM T.R. WENIGER, INC. TO REPAIR TRASH RACKS AT THE RIVER STREET PUMP STATION

Councilmember Bieber introduced and offered for adoption the following Resolution; seconded by Councilmember Booker:

WHEREAS, the pump station on River Street in the Borough of Sea Bright is in need of repairs to the trash rack; and

WHEREAS, in connection therewith, Borough Engineer Gregory Blash requested proposals from (3) contractors to make said repairs and received (2) completed proposals from 1) T.R. Weniger Inc., in the amount of \$10,940.00 and 2) T&T Commonwealth Construction Co, Inc. in the amount of \$13,822.00; and

WHEREAS, the Borough Administrator and Borough Engineer have reviewed the proposals and recommend Council approve the proposal received from T.R. Weniger, Inc., attached hereto.

CERTIFICATION OF FUNDS

I, Michael J. Bascom, Chief Financial Officer of the Borough of Sea Bright, do hereby certify that funds in the amount of \$10,940.00 will be available in Budget Line Item S0655507-001 for the purposes stated herein.

MÍCHAEL J. BASCOM, CFO

NOW, THEREFORE, BE IT RESOLVED by the Borough Council of the Borough of Sea Bright, in the County of Monmouth, State of New Jersey, that the Borough Council hereby approves the proposal submitted by T.R. Weniger, Inc. to make repairs to the River Street Pump Station, for sum of \$10,940.00; and

BE IT FURTHER RESOLVED that a certified copy of this Resolution be forwarded to the following:

- 1. Leon S. Avakian
- 2. Finance Manager
- 3. Department of Public Works

Roll Call:


Bieber, Yes Booker, Yes Catalano, Yes Gorman, Yes Keeler, Absent Lamia Yes

August 15, 2023

CERTIFICATION

I, Christine Pfeiffer, Borough Clerk, do hereby certify that the foregoing is a Resolution adopted by the Borough Council of the Borough of Sea Bright, County of Monmouth, State of New Jersey, at a Council Meeting held on August 15, 2023.

Christine Pfeiffer, Borough Clerk





PROPOSAL

May 10th, 2023

David Bahrle Director - Department of Public Works Borough of Sea Bright 1099 Ocean Avenue Sea Bright, NJ 07760 dbahrle@seabrightnj.org 732-890-5922

RE: Trash Rack Repairs - River St. Pump Station

We hereby propose to furnish labor, equipment, and materials for the completion of the following;

- Mobilization to site
- Time for completion 2 days
- Prevailing wage labor rates apply

Day 1:

- Installation of pump station bypass
 - o Install 15" plug
 - Provide 6" diesel pump with floats
 - Provide misc. piping to connect to existing 6" cam lock bypass connection
- Wet well to be cleaned by others after bypass operations installed
 - TRW to provide assistance with onsite crew to clean wet well
- Inspect trash rack for damage at hinged connection and wall connection
- Upon inspection, provide recommendations for repairs for approval
 - Mechanical repairs limited to drilling/bolting/fastening with stainless hardware
 - Welding repairs not to be performed due to hazardous location
- Procure necessary hardware for repairs
 - Repair materials to be invoiced against allowance of \$500.00
- Remove bypass and return to normal operation

Day 2:

- Resume bypass operation
- Perform mechanical repairs to trash rack to return to operation
- Upon repairs being performed, reset trash rack into existing channels and ensure operation
- Remove bypass operations
- General site cleaning of disturbed areas

TOTAL

\$10,940.00

Breakdown of pricing:

- Labor 3 man crew (Confined Space Entry), 48 hours total @ \$125.00/hr. prevailing; \$6,000.00
- Equipment Service Truck, Rigging, Chainfalls, Misc. Tools \$1,325.00/day; \$2,650.00
- Allowance for Repairs \$500.00
- Bypass Pumps and Hoses \$1,790.00

Regards, Timothy Weniger T. R. WENIGER, INC.